



UNIVERSITI TUN HUSSEIN ONN MALAYSIA

**FINAL EXAMINATION
SEMESTER I
SESSION 2017/2018**

COURSE NAME : WASTEWATER ENGINEERING
DESIGN

COURSE CODE : BFA40403

PROGRAMME CODE : BFF

EXAMINATION DATE : DECEMBER 2017 / JANUARY 2018

DURATION : 3 HOURS

INSTRUCTION : ANSWER ALL QUESTIONS

TERBUKA

THIS QUESTION PAPER CONSISTS OF **FIVE (5)** PAGES

Q1 (a) In general, the wastewater flowing to a wastewater treatment plant is divided into four wastewater types according to its source. List all **FOUR (4)** types of wastewater and give an example for each. (5 marks)

(b) A mechanically cleaned screen has bars 5 mm thick and 30 mm clear spaces between the bars. If the velocity through the bars is 0.90 m/s, determine:

(i) approach velocity (2 marks)

(ii) head loss through the screen (3 marks)

(c) A municipal wastewater treatment plant has an average flow of 0.473 m³/s, and two aerated grit chambers, are to be designed. Dual units should be provided for flexibility in operation, since one could be used when the other requires temporary maintenance. During normal operation, both chambers should be used. Each chamber is a rectangular tank with spiral-roll flow. Peak flow is 2.3 times the average flow. The tank width is 1.5 times the depth, and the length is 4.0 times the width. Determine:

(i) theoretical dimensions of the tanks, if the detention time is 3 minutes. (7 marks)

(ii) total air flow, if 0.3 m³/min per meter of tank length is to be provided. (8 marks)

Q2 An in-line equalization tank is to be designed for a wastewater treatment plant. From plant records, a compilation has been made that register the hourly flowrate versus hour of the day as shown in **Table 1**. Calculate the size of in-line equalization tank required to equalize the flowrate and the time period when the equalization tank is empty. Provide a 20% excess capacity as a safety factor. (25 marks)

Q3 (a) Describe each phase of microbial growth pattern as shown in **Figure Q3(a)**. (5 marks)

(b) Assuming the food to microorganisms ratio equal to 0.35 and hydraulic residence time of 7 hours, compute the value of MLVSS to be maintained in the reactor of a conventional activated sludge plant designed to treat 7000 m³/d settled wastewater with 230 mg/L of BOD₅. Then, determine:

(i) volume of the reactor (2 marks)



(ii) daily amount of food (BOD₅) fed to the reactor (3 marks)

- (c) A town has been directed to upgrade its primary wastewater treatment facility to a secondary plant that can meet an effluent standard of 25.0 mg/L BOD₅ and 25.0 mg/L suspended solids. A completely mixed activated sludge system had been selected. Assumed that BOD₅ of the suspended solids is estimated as equal to 60% of the suspended solids concentration. Two data below are available from the existing primary plant.

Flow = 0.140 m³/s
 BOD₅ = 80.0 mg/L

Assuming the following values for the growth constants:
 K_s = 80 mg/L BOD₅, μ_m = 2.5/day, k_d = 0.050/day.

Calculate:

- (i) allowable soluble BOD₅ (5 marks)
- (ii) mean cell-residence time (5 marks)
- (iii) volume of the aeration tank (5 marks)

- Q4** (a) Disinfection is used in wastewater treatment to kill pathogens (disease-causing microorganisms) present in wastewater that would cause mild to fatal illness if ingested. Chlorination is the most popular method applied for disinfection process. However, there are other methods of disinfection besides chlorination that can be applied in conventional and advanced wastewater treatment facility namely ozonation and ultraviolet (UV). Explain briefly the advantages and disadvantages of UV method for disinfection in wastewater treatment system.

(5 marks)

- (b) Define these processes for sludge management:

- (i) Thickening (2 marks)
- (ii) Stabilization (2 marks)
- (iii) Conditioning (2 marks)
- (iv) Dewatering (2 marks)



- (c) A primary circular clarifier for a municipal wastewater treatment plant is to be designed for an average flow of 7000 m³/d. The regulatory agency criteria for primary clarifiers are as follows:

Peak overflow rate = $85 \text{ m}^3/\text{m}^2 \cdot \text{d}$

Average overflow rate = $35 \text{ m}^3/\text{m}^2 \cdot \text{d}$

Minimum side water depth = 2.5 m

Peak weir loading = $380 \text{ m}^3/\text{m} \cdot \text{d}$

Ratio of the peak hourly flow to the average hourly flow is 2.5.

Determine:

- (i) diameter of clarifier (5 marks)
- (ii) peak weir loading (5 marks)
- (d) Based on your calculations in (c), compare and explain the calculated values with the regulatory criteria. (2 marks)

– END OF QUESTIONS –

TERBUKA

